


POLLUTION MONITORING DATA
Jerilderie Sewerage Treatment Works



Environment Protection Licence No. 1692

Link to full licence on EPA website: [Jerilderie Licence 1692](#)

Licensee: Murrumbidgee Council

Licensee's Address: PO Box 96, Jerilderie NSW 2716

Facility Address: Wilson Road, Jerilderie NSW 2716

Date Sample: 12 March 2024

Date Obtained: 15 March 2024

Date Published: 23 April 2024

| Pollutant | Unit | Monitoring frequency required by licence | Measurement | Licence Limits |
|----------------------------------|-----------------------------|---|--------------------|-----------------------|
| Biochemical Oxygen Demand | Milligrams per litre | Quarterly | 20 | 20 |
| Faecal Coliforms | Cfu/100mL | Quarterly | 66 | |
| Conductivity | Microsiemens per centimetre | Quarterly | 1310 | |
| Nitrogen (total) | Milligrams per litre | Quarterly | 16 | |
| Oil and Grease | Milligrams per litre | Quarterly | 6 | 10 |
| pH | Milligrams per litre | Quarterly | 6.7 | |
| Phosphorus (total) | Milligrams per litre | Quarterly | 5.39 | |
| Total Suspended Solids | Milligrams per litre | Quarterly | 700 | 30 |