


CURRENT POLLUTION MONITORING DATA
DARLINGTON POINT SEWAGE TREATMENT SYSTEM

Darlington Point Sewerage Treatment Works



Environment Protection Licence No. : 169 6260

Link to full licence on EPA website:

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=33729&SYSUID=1&LICID=6260>

Licensee: Murrumbidgee Council, PO Box 5 Darlington Point NSW 2706
Address of Facility: Boyd Street, Darlington Point NSW

Sampling Point 1

Date Sample: 11 March 2024
Date Obtained: 15 March 2024
Date Published: 23 April 2024

Pollutant	Unit	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	29	10
Chlorine Residual – Free	Milligrams per litre	<0.5	0.5
Nitrogen (total)	Milligrams per litre	6	10
Nitrate	Milligrams per litre	1.5	0.1
Oil and Grease	Milligrams per litre	1	10
pH	Milligrams per litre	6.8	6.5-8.5
Phosphorus (total)	Milligrams per litre	2.87	10
Faecal Coliforms	CFU/100ml	30	200
Total Kjeldahl Nitrogen	Milligrams per litre	4	2
Total Suspended Solids	Milligrams per litre	25	15