


**ARCHIVED POLLUTION MONITORING DATA
FROM 31 MARCH 2012 - PRESENT**

Jerilderie Sewerage Treatment Works



Environment Protection Licence No. 1692

Link to full licence on EPA website: [Jerilderie Licence 1692](#)

Licensee: Murrumbidgee Council

Licensee's Address: PO Box 96, Jerilderie NSW 2716

Facility Address: Wilson Road, Jerilderie NSW 2716

Date Sample: 12 March 2024
Date Obtained: 15 March 2024
Date Published: 23 April 2024

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	20	20
Faecal Coliforms	Cfu/100mL	Quarterly	66	
Conductivity	Microsiemens per centimetre	Quarterly	1310	
Nitrogen (total)	Milligrams per litre	Quarterly	16	
Oil and Grease	Milligrams per litre	Quarterly	6	10
pH	Milligrams per litre	Quarterly	6.7	
Phosphorus (total)	Milligrams per litre	Quarterly	5.39	
Total Suspended Solids	Milligrams per litre	Quarterly	700	30

Date Sample: 5 December 2023
Date Obtained: 11 December 2023
Date Published: 21 December 2023

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	22	20
Faecal Coliforms	Cfu/100mL	Quarterly	10	
Conductivity	Microsiemens per centimetre	Quarterly	672	
Nitrogen (total)	Milligrams per litre	Quarterly	8	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	9.5	
Phosphorus (total)	Milligrams per litre	Quarterly	1.89	
Total Suspended Solids	Milligrams per litre	Quarterly	6	30

Monitoring Point 4

Date Sample: 20 September 2023
Date Obtained: 25 September 2023
Date Published: 25 October 2023

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	21	20
Faecal Coliforms	Cfu/100mL	Quarterly	16	
Conductivity	Microsiemens per centimetre	Quarterly	1080	
Nitrogen (total)	Milligrams per litre	Quarterly	12	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	6.7	
Phosphorus (total)	Milligrams per litre	Quarterly	9.87	
Total Suspended Solids	Milligrams per litre	Quarterly	64	30

Monitoring Point 4

Date Sample: 13 June 2023

Date Obtained: 15 June 2023

Date Published: 11 July 2023

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	4	20
Faecal Coliforms	Cfu/100mL	Quarterly	112	
Conductivity	Microsiemens per centimetre	Quarterly	1130	
Nitrogen (total)	Milligrams per litre	Quarterly	10	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	7.3	
Phosphorus (total)	Milligrams per litre	Quarterly	9.16	
Total Suspended Solids	Milligrams per litre	Quarterly	41	30

Monitoring Point 4

Date Sample: 14 March 2023

Date Obtained: 20 April 2023

Date Published: 5 May 2023

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	24	20
Faecal Coliforms	Cfu/100mL	Quarterly	63000	
Conductivity	Microsiemens per centimetre	Quarterly	1080	
Nitrogen (total)	Milligrams per litre	Quarterly	12	
Oil and Grease	Milligrams per litre	Quarterly	27	10
pH	Milligrams per litre	Quarterly	7.3	
Phosphorus (total)	Milligrams per litre	Quarterly	10.4	
Total Suspended Solids	Milligrams per litre	Quarterly	33	30

Monitoring Point 4

Date Sample: 06 December 2022

Date Obtained: 07 December 2022

Date Published: 10 January 2022

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	16	20
Faecal Coliforms	Cfu/100mL	Quarterly	24400	
Conductivity	Microsiemens per centimetre	Quarterly	812	
Nitrogen (total)	Milligrams per litre	Quarterly	12	
Oil and Grease	Milligrams per litre	Quarterly	2	10
pH	Milligrams per litre	Quarterly	8.1	
Phosphorus (total)	Milligrams per litre	Quarterly	5.31	
Total Suspended Solids	Milligrams per litre	Quarterly	30	30

Monitoring Point 4

Date Sample: 20 September 2022

Date Obtained: 21 September 2022

Date Published: 22 September 2022

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	72	20
Faecal Coliforms	Cfu/100mL	Quarterly	8	
Conductivity	Microsiemens per centimetre	Quarterly	1050	
Nitrogen (total)	Milligrams per litre	Quarterly	57	
Oil and Grease	Milligrams per litre	Quarterly	3	10
pH	Milligrams per litre	Quarterly	7.9	
Phosphorus (total)	Milligrams per litre	Quarterly	9.13	
Total Suspended Solids	Milligrams per litre	Quarterly	59	30

Monitoring Point 4

Date Sample: 14 June 2022

Date Obtained: 9 July 2022

Date Published: 19 July 2022

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	54	20
Faecal Coliforms	Cfu/100mL	Quarterly	1480000	
Conductivity	Microsiemens per centimetre	Quarterly	1200	
Nitrogen (total)	Milligrams per litre	Quarterly	62	
Oil and Grease	Milligrams per litre	Quarterly	2	10
pH	Milligrams per litre	Quarterly	7.00	
Phosphorus (total)	Milligrams per litre	Quarterly	7.85	
Total Suspended Solids	Milligrams per litre	Quarterly	88	30

Monitoring Point 4

Date Sample: 12 April 2022

Date Obtained: 14 April 2022

Date Published: 25 May 2022

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	29	20
Faecal Coliforms	Cfu/100mL	Quarterly	1600	
Conductivity	Microsiemens per centimetre	Quarterly	895	
Nitrogen (total)	Milligrams per litre	Quarterly	45	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	7.3	
Phosphorus (total)	Milligrams per litre	Quarterly	6.74	
Total Suspended Solids	Milligrams per litre	Quarterly	32	30

Monitoring Point 4

Date Sample: 11 January 2022

Date Obtained: 16 February 2022

Date Published: 29 April 2022

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	9	20
Faecal Coliforms	Cfu/100mL	Quarterly	1640	
Conductivity	Microsiemens per centimetre	Quarterly	898	
Nitrogen (total)	Milligrams per litre	Quarterly	25	
Oil and Grease	Milligrams per litre	Quarterly	2	10
pH	Milligrams per litre	Quarterly	7.2	
Phosphorus (total)	Milligrams per litre	Quarterly	6.54	
Total Suspended Solids	Milligrams per litre	Quarterly	40	30

Monitoring Point 4

Date Sample: 8 December 2021

Date Obtained: 21 December 2021

Date Published: 23 December 2021

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	21	20
Faecal Coliforms	Cfu/100mL	Quarterly	211000	
Conductivity	Microsiemens per centimetre	Quarterly	910	
Nitrogen (total)	Milligrams per litre	Quarterly	27	
Oil and Grease	Milligrams per litre	Quarterly	3	10
pH	Milligrams per litre	Quarterly	7.5	
Phosphorus (total)	Milligrams per litre	Quarterly	6.31	
Total Suspended Solids	Milligrams per litre	Quarterly	27	30

Monitoring Point 4

Date Sample: 25 May 2021

Date Obtained: 21 July 2021

Date Published: 22 July 2021

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	35	20
Faecal Coliforms	Cfu/100mL	Quarterly	356000	
Conductivity	Microsiemens per centimetre	Quarterly	960	
Nitrogen (total)	Milligrams per litre	Quarterly	48	
Oil and Grease	Milligrams per litre	Quarterly	5	10
pH	Milligrams per litre	Quarterly	7.5	
Phosphorus (total)	Milligrams per litre	Quarterly	9.22	
Total Suspended Solids	Milligrams per litre	Quarterly	48	30

Monitoring Point 4

Date Sample: 22 December 2020

Date Obtained: 23 December 2020

Date Published: 3 March 2021

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	19	20
Faecal Coliforms	Cfu/100mL	Quarterly	222000	
Conductivity	Microsiemens per centimetre	Quarterly	994	
Nitrogen (total)	Milligrams per litre	Quarterly	53	
Oil and Grease	Milligrams per litre	Quarterly	3	10
pH	Milligrams per litre	Quarterly	7.6	
Phosphorus (total)	Milligrams per litre	Quarterly	7.46	
Total Suspended Solids	Milligrams per litre	Quarterly	34	30

Monitoring Point 4

Date Sample: 20 October 2020

Date Obtained: 6 November 2020

Date Published: 19 November 2020

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	7	20
Faecal Coliforms	Cfu/100mL	Quarterly	111	
Conductivity	Microsiemens per centimetre	Quarterly	848	
Nitrogen (total)	Milligrams per litre	Quarterly	7	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	8	
Phosphorus (total)	Milligrams per litre	Quarterly	12.4	
Total Suspended Solids	Milligrams per litre	Quarterly	135	30

Monitoring Point 4

Date Sample: 23 June 2020

Date Obtained: 24 July 2020

Date Published: 29 July 2020

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	16	20
Faecal Coliforms	Cfu/100mL	Quarterly	260000	
Conductivity	Microsiemens per centimetre	Quarterly	881	
Nitrogen (total)	Milligrams per litre	Quarterly	34	
Oil and Grease	Milligrams per litre	Quarterly	5	10
pH	Milligrams per litre	Quarterly	6.9	
Phosphorus (total)	Milligrams per litre	Quarterly	8.10	
Total Suspended Solids	Milligrams per litre	Quarterly	123	30

Monitoring Point 4

Date Sample: 7 April 2020

Date Obtained: 4 May 2020

Date Published: 5 May 2020

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	49	20
Faecal Coliforms	Cfu/100mL	Quarterly	2000000	
Conductivity	Microsiemens per centimetre	Quarterly	735	
Nitrogen (total)	Milligrams per litre	Quarterly	39	
Oil and Grease	Milligrams per litre	Quarterly	2	10
pH	Milligrams per litre	Quarterly	7.6	
Phosphorus (total)	Milligrams per litre	Quarterly	5.4	
Total Suspended Solids	Milligrams per litre	Quarterly	36	30

Monitoring Point 4

Date Sample: 28 January 2020

Date Obtained: 29 January 2020

Date Published: 13 March 2020

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	40	20
Faecal Coliforms	Cfu/100mL	Quarterly	81000	
Conductivity	Microsiemens per centimetre	Quarterly	985	
Nitrogen (total)	Milligrams per litre	Quarterly	43	
Oil and Grease	Milligrams per litre	Quarterly	9	10
pH	Milligrams per litre	Quarterly	7.5	
Phosphorus (total)	Milligrams per litre	Quarterly	7.59	
Total Suspended Solids	Milligrams per litre	Quarterly	80	30

Monitoring Point 4

Date Sample: 19 November 2019

Date Obtained: 20 November 2019

Date Published: 5 January 2020

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	34	20
Faecal Coliforms	Cfu/100mL	Quarterly	<1	
Conductivity	Microsiemens per centimetre	Quarterly	890	
Nitrogen (total)	Milligrams per litre	Quarterly	49	
Oil and Grease	Milligrams per litre	Quarterly	8	10
pH	Milligrams per litre	Quarterly	7.7	
Phosphorus (total)	Milligrams per litre	Quarterly	10.5	

Total Suspended Solids	Milligrams per litre	Quarterly	40	30
-------------------------------	----------------------	-----------	----	----

Date Sample: 8 October 2019
Date Obtained: 14 October 2019
Date Published: 19 October 2019

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	<2	20
Conductivity	Microsiemens per centimetre	Quarterly		
Nitrogen (total)	Milligrams per litre	Quarterly	2	
Oil and Grease	Milligrams per litre	Quarterly	3	10
pH	Milligrams per litre	Quarterly	7.8	
Phosphorus (total)	Milligrams per litre	Quarterly	7.98	
Total Suspended Solids	Milligrams per litre	Quarterly	7	30

Date Sample: 19 June 2019
Date Obtained: 20 June 2019
Date Published: 5 July 2019

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	<2	20
Conductivity	Microsiemens per centimetre	Quarterly	655	
Nitrogen (total)	Milligrams per litre	Quarterly	I/S	
Oil and Grease	Milligrams per litre	Quarterly	<1	10
pH	Milligrams per litre	Quarterly	8.5	
Phosphorus (total)	Milligrams per litre	Quarterly	I/S	
Total Suspended Solids	Milligrams per litre	Quarterly	I/S	30

Monitoring Point 4

Date Sample: 19 May 2019
Date Obtained: 22 May 2019
Date Published: 6 June 2019

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	40	20
Conductivity	Microsiemens per centimetre	Quarterly	903	
Nitrogen (total)	Milligrams per litre	Quarterly	49	
Oil and Grease	Milligrams per litre	Quarterly	11	10
pH	Milligrams per litre	Quarterly	7.5	
Phosphorus (total)	Milligrams per litre	Quarterly	8.28	
Total Suspended Solids	Milligrams per litre	Quarterly	52	30

Monitoring Point 4

Date Sample: 19 March 2019
Date Obtained: 26 March 2019
Date Published: 16 April 2019

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	43	20
Conductivity	Microsiemens per centimetre	Quarterly	772	
Nitrogen (total)	Milligrams per litre	Quarterly	34	
Oil and Grease	Milligrams per litre	Quarterly	10	10
pH	Milligrams per litre	Quarterly	7.4	
Phosphorus (total)	Milligrams per litre	Quarterly	5.12	
Total Suspended Solids	Milligrams per litre	Quarterly	30	30

Monitoring Point 4

Date Sample: 26 February 2019
Date Obtained: 26 February 2019
Date Published: 12 March 2019

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	18	20
Conductivity	Microsiemens per centimetre	Quarterly	1020	
Nitrogen (total)	Milligrams per litre	Quarterly	14	
Oil and Grease	Milligrams per litre	Quarterly	4	10
pH	Milligrams per litre	Quarterly	7.6	
Phosphorus (total)	Milligrams per litre	Quarterly	7.76	
Total Suspended Solids	Milligrams per litre	Quarterly	695	30

Monitoring Point 4

Date Sample: 21 August 2018
Date Obtained: 21 August 2018
Date Published: 11 September 2018

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	<2	20
Conductivity	Microsiemens per centimetre	Quarterly	860	
Faecal Coliforms	Colony forming units per 100 millilitres	Quarterly	70	
Nitrogen (total)	Milligrams per litre	Quarterly	15	
Oil and Grease	Milligrams per litre	Quarterly	2	10
pH	Milligrams per litre	Quarterly	7.9	
Phosphorus (total)	Milligrams per litre	Quarterly	8.85	
Total Suspended Solids	Milligrams per litre	Quarterly	20	30

Monitoring Point 4

Date Sample: 20 March 2018

Date Obtained: 20 March 2018

Date Published: 13 April 2018

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	58	20
Conductivity	Microsiemens per centimetre	Quarterly	1040	
Faecal Coliforms	Colony forming units per 100 millilitres	Quarterly		
Nitrogen (total)	Milligrams per litre	Quarterly	32	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	7.8	
Phosphorus (total)	Milligrams per litre	Quarterly	9.3	
Total Suspended Solids	Milligrams per litre	Quarterly	276	30

Monitoring Point 4

Date Sample: 21 November 2017

Date Obtained: 21 November 2017

Date Published: 14 December 2017

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	6	20
Conductivity	Microsiemens per centimetre	Quarterly	1210	
Nitrogen (total)	Milligrams per litre	Quarterly	9	
Oil and Grease	Milligrams per litre	Quarterly	<1	10
pH	Milligrams per litre	Quarterly	7.6	
Phosphorus (total)	Milligrams per litre	Quarterly	15.7	
Total Suspended Solids	Milligrams per litre	Quarterly	33	30

Monitoring Point 4

Date Sample: 5 September 2017

Date Obtained: 19 September 2017

Date Published: 3 October 2017

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	7	20
Conductivity	Microsiemens per centimetre	Quarterly	1050	
Nitrogen (total)	Milligrams per litre	Quarterly	31	
Oil and Grease	Milligrams per litre	Quarterly	<1	10
pH	Milligrams per litre	Quarterly	7.7	
Phosphorus (total)	Milligrams per litre	Quarterly	9.18	
Total Suspended Solids	Milligrams per litre	Quarterly	13	30

Monitoring Point 4

Date Sample: 2 May 2017

Date Obtained: 15 May 2017

Date Published: 2 June 2017

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	29	20
Conductivity	Microsiemens per centimetre	Quarterly	827	
Nitrogen (total)	Milligrams per litre	Quarterly	40	
Oil and Grease	Milligrams per litre	Quarterly	13	10
pH	Milligrams per litre	Quarterly	7.5	
Phosphorus (total)	Milligrams per litre	Quarterly	6.76	
Total Suspended Solids	Milligrams per litre	Quarterly	29	30

Monitoring Point 4

Date Sample: 14 March 2017

Date Obtained: 22 March 2017

Date Published: 24 March 2017

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	33 *	20
Conductivity	Microsiemens per centimetre	Quarterly	1470	
Nitrogen (total)	Milligrams per litre	Quarterly	20	
Oil and Grease	Milligrams per litre	Quarterly	4	10
pH	Milligrams per litre	Quarterly	8.1	
Phosphorus (total)	Milligrams per litre	Quarterly	8.55	
Total Suspended Solids	Milligrams per litre	Quarterly	574*	30

* Alternative sampling point used and site cleaned two days prior to testing accounts for TSS & BOD levels being high.

Monitoring Point 4

Date Sample: 30 August 2016

Date Obtained: 13 September 2016

Date Published: 16 September 2016

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	4	20
Conductivity	Microsiemens per centimetre	Quarterly	656	
Nitrogen (total)	Milligrams per litre	Quarterly	9	
Oil and Grease	Milligrams per litre	Quarterly	3	10
pH	Milligrams per litre	Quarterly	7.7	
Phosphorus (total)	Milligrams per litre	Quarterly	7.33	
Total Suspended Solids	Milligrams per litre	Quarterly	9	30

Monitoring Point 4

Date Sample: 30 August 2016

Date Obtained: 13 September 2016

Date Published: 16 September 2016

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Demand Oxygen	Milligrams per litre	Quarterly	4	20
Conductivity	Microsiemens per centimetre	Quarterly	656	
Nitrogen (total)	Milligrams per litre	Quarterly	9	
Oil and Grease	Milligrams per litre	Quarterly	3	10
pH	Milligrams per litre	Quarterly	7.7	
Phosphorus (total)	Milligrams per litre	Quarterly	7.33	
Total Suspended Solids	Milligrams per litre	Quarterly	9	30

Monitoring Point 4

Date Sample: 17 May 2016

Date Obtained: 17 May 2016

Date Published: 10 June 2016

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Demand Oxygen	Milligrams per litre	Quarterly	12	20
Conductivity	Microsiemens per centimetre	Quarterly	771	
Nitrogen (total)	Milligrams per litre	Quarterly	12	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	7.6	
Phosphorus (total)	Milligrams per litre	Quarterly	13.6	
Total Suspended Solids	Milligrams per litre	Quarterly	118	30

Monitoring Point 4

Date Sample: 22 March 2016

Date Obtained: 22 March 2016

Date Published: 10 June 2016

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Demand Oxygen	Milligrams per litre	Quarterly	13	20
Conductivity	Microsiemens per centimetre	Quarterly	993	
Nitrogen (total)	Milligrams per litre	Quarterly	5	
Oil and Grease	Milligrams per litre	Quarterly	2	10
pH	Milligrams per litre	Quarterly	8.4	
Phosphorus (total)	Milligrams per litre	Quarterly	7.19	
Total Suspended Solids	Milligrams per litre	Quarterly	91	30

Monitoring Point 4

Date Sample: 1 December 2015

Date Obtained: 11 December 2015

Date Published: 11 December 2015

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	22	20
Conductivity	Microsiemens per centimetre	Quarterly	1220	
Nitrogen (total)	Milligrams per litre	Quarterly	10	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	8.3	
Phosphorus (total)	Milligrams per litre	Quarterly	14.2	
Total Suspended Solids	Milligrams per litre	Quarterly	168	30

Monitoring Point 4

Date Sample: 18 August 2015

Date Obtained: 18 August 2015

Date Published: 1 September 2015

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	3	20
Conductivity	Microsiemens per centimetre	Quarterly	733	
Nitrogen (total)	Milligrams per litre	Quarterly	15	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	7.9	
Phosphorus (total)	Milligrams per litre	Quarterly	8.23	
Total Suspended Solids	Milligrams per litre	Quarterly	49	30

Monitoring Point 4

Date Sample: 9 June 2015

Date Obtained: 9 June 2015

Date Published: 30 June 2015

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	2	20
Conductivity	Microsiemens per centimetre	Quarterly	731	
Nitrogen (total)	Milligrams per litre	Quarterly	9	
Oil and Grease	Milligrams per litre	Quarterly	2	10
pH	Milligrams per litre	Quarterly	8.0	
Phosphorus (total)	Milligrams per litre	Quarterly	9.41	
Total Suspended Solids	Milligrams per litre	Quarterly	65	30

Monitoring Point 4

Date Sample: 14 April 2015

Date Obtained: 15 April 2015

Date Published: 27 April 2015

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	11	20
Conductivity	Microsiemens per centimetre	Quarterly	311	
Nitrogen (total)	Milligrams per litre	Quarterly	3	
Oil and Grease	Milligrams per litre	Quarterly	2	10
pH	Milligrams per litre	Quarterly	7.2	
Phosphorus (total)	Milligrams per litre	Quarterly	3.83	
Total Suspended Solids	Milligrams per litre	Quarterly	292	30

Monitoring Point 4

Date Sample: 15 January 2015

Date Obtained: 20 January 2015

Date Published: 3 February 2015

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	47	20
Conductivity	Microsiemens per centimetre	Quarterly	775	
Nitrogen (total)	Milligrams per litre	Quarterly	40	
Oil and Grease	Milligrams per litre	Quarterly	15	10
pH	Milligrams per litre	Quarterly	7.9	
Phosphorus (total)	Milligrams per litre	Quarterly	6.88	
Total Suspended Solids	Milligrams per litre	Quarterly	43	30

Monitoring Point 4

Date Sample: 14 September 2014

Date Obtained: 23 September 2014

Date Published: 7 October 2014

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	74
Conductivity	Microsiemens per centimetre	Quarterly	896
Nitrogen (total)	Milligrams per litre	Quarterly	47
Oil and Grease	Milligrams per litre	Quarterly	18
pH	Milligrams per litre	Quarterly	7.7
Phosphorus (total)	Milligrams per litre	Quarterly	7.34
Total Suspended Solids	Milligrams per litre	Quarterly	51

Monitoring Point 4

Date Sample: 3 June 2014

Date Obtained: 17 June 2014

Date Published: 18 June 2014

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	70
Conductivity	Microsiemens per centimetre	Quarterly	997
Nitrogen (total)	Milligrams per litre	Quarterly	27
Oil and Grease	Milligrams per litre	Quarterly	12
pH	Milligrams per litre	Quarterly	7.9
Phosphorus (total)	Milligrams per litre	Quarterly	5.21
Total Suspended Solids	Milligrams per litre	Quarterly	60

Monitoring Point 4

Date Sample: 8 April 2014

Date Obtained: 28 April 2014

Date Published: 29 April 2014

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	47
Conductivity	Microsiemens per centimetre	Quarterly	684
Nitrogen (total)	Milligrams per litre	Quarterly	38
Oil and Grease	Milligrams per litre	Quarterly	8
pH	Milligrams per litre	Quarterly	7.5
Phosphorus (total)	Milligrams per litre	Quarterly	6.34
Total Suspended Solids	Milligrams per litre	Quarterly	41

Monitoring Point 4

Date Sample: 14 November 2013

Date Obtained: 27 November 2013

Date Published: 3 December 2013

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	29
Conductivity	Microsiemens per centimetre	Quarterly	866
Nitrogen (total)	Milligrams per litre	Quarterly	43
Oil and Grease	Milligrams per litre	Quarterly	6
pH	Milligrams per litre	Quarterly	7.5
Phosphorus (total)	Milligrams per litre	Quarterly	5.88
Total Suspended Solids	Milligrams per litre	Quarterly	32

Monitoring Point 4

Date Sample: 29 August 2013

Date Obtained: 12 September 2013

Date Published: 18 September 2013

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	100
Conductivity	Microsiemens per centimetre	Quarterly	1000
Nitrogen (total)	Milligrams per litre	Quarterly	46
Oil and Grease	Milligrams per litre	Quarterly	24
pH	Milligrams per litre	Quarterly	7.8
Phosphorus (total)	Milligrams per litre	Quarterly	7.67
Total Suspended Solids	Milligrams per litre	Quarterly	73

Monitoring Point 4

Date Sample: 16 May 2013

Date Obtained: 27 May 2013

Date Published: 21 May 2013

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	61
Conductivity	Microsiemens per centimetre	Quarterly	738
Nitrogen (total)	Milligrams per litre	Quarterly	42
Oil and Grease	Milligrams per litre	Quarterly	2
pH	Milligrams per litre	Quarterly	7.3
Phosphorus (total)	Milligrams per litre	Quarterly	5.99
Total Suspended Solids	Milligrams per litre	Quarterly	54

Monitoring Point 4

Date Sample: 21 March 2013

Date Obtained: 4 April 2013

Date Published: 8 April 2013

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	31
Conductivity	Microsiemens per centimetre	Quarterly	839
Nitrogen (total)	Milligrams per litre	Quarterly	33
Oil and Grease	Milligrams per litre	Quarterly	17
pH	Milligrams per litre	Quarterly	7.2
Phosphorus (total)	Milligrams per litre	Quarterly	5.99
Total Suspended Solids	Milligrams per litre	Quarterly	34

Monitoring Point 4

Date Sample: 14 November 2012

Date Obtained: 27 November 2012

Date Published: 4 December 2012

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	71
Conductivity	Microsiemens per centimetre	Quarterly	914
Nitrogen (total)	Milligrams per litre	Quarterly	51
Oil and Grease	Milligrams per litre	Quarterly	1
pH	Milligrams per litre	Quarterly	7.7
Phosphorus (total)	Milligrams per litre	Quarterly	7.2
Total Suspended Solids	Milligrams per litre	Quarterly	43

Monitoring Point 4

Date Sample: 16 August 2012

Date Obtained: 28 August 2012

Date Published: 31 August 2012

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	100
Conductivity	Microsiemens per centimetre	Quarterly	1020
Nitrogen (total)	Milligrams per litre	Quarterly	47
Oil and Grease	Milligrams per litre	Quarterly	20
pH	Milligrams per litre	Quarterly	8.0
Phosphorus (total)	Milligrams per litre	Quarterly	8.4
Total Suspended Solids	Milligrams per litre	Quarterly	64

Monitoring Point 4

Date Sample: 20 June 2012

Date Obtained: 3 July 2012

Date Published: 5 July 2012

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	101
Conductivity	Microsiemens per centimetre	Quarterly	1090
Nitrogen (total)	Milligrams per litre	Quarterly	83
Oil and Grease	Milligrams per litre	Quarterly	17
pH	Milligrams per litre	Quarterly	7.6
Phosphorus (total)	Milligrams per litre	Quarterly	8.04
Total Suspended Solids	Milligrams per litre	Quarterly	54