

**ARCHIVED POLLUTION MONITORING DATA  
FROM 31 MARCH 2012 - PRESENT**

**Jerilderie Sewerage Treatment Works**



**Environment Protection Licence No. 1692**

Link to full licence on EPA website: [Jerilderie Licence 1692](#)

**Licensee:** Murrumbidgee Council

**Licensee's Address:** PO Box 96, Jerilderie NSW 2716

**Facility Address:** Wilson Road, Jerilderie NSW 2716

**Date Sample:** 11 June 2024  
**Date Obtained:** 13 June 2024  
**Date Published:** 24 June 2024

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	9	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	78	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	882	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	7	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	2	10
<b>pH</b>	Milligrams per litre	Quarterly	7.4	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	11.4	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	21	30

**Date Sample:** 12 March 2024  
**Date Obtained:** 15 March 2024  
**Date Published:** 23 April 2024

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	20	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	66	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1310	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	16	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	6	10
<b>pH</b>	Milligrams per litre	Quarterly	6.7	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	5.39	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	700	30

**Date Sample:** 5 December 2023  
**Date Obtained:** 11 December 2023  
**Date Published:** 21 December 2023

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	22	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	10	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	672	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	8	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	1	10
<b>pH</b>	Milligrams per litre	Quarterly	9.5	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	1.89	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	6	30

#### Monitoring Point 4

**Date Sample:** 20 September 2023

**Date Obtained:** 25 September 2023

**Date Published:** 25 October 2023

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	21	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	16	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1080	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	12	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	1	10
<b>pH</b>	Milligrams per litre	Quarterly	6.7	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	9.87	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	64	30

#### Monitoring Point 4

**Date Sample:** 13 June 2023

**Date Obtained:** 15 June 2023

**Date Published:** 11 July 2023

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	4	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	112	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1130	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	10	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	1	10
<b>pH</b>	Milligrams per litre	Quarterly	7.3	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	9.16	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	41	30

#### Monitoring Point 4

**Date Sample:** 14 March 2023

**Date Obtained:** 20 April 2023

**Date Published:** 5 May 2023

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	24	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	63000	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1080	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	12	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	27	10
<b>pH</b>	Milligrams per litre	Quarterly	7.3	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	10.4	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	33	30

#### Monitoring Point 4

**Date Sample:** 06 December 2022  
**Date Obtained:** 07 December 2022  
**Date Published:** 10 January 2022

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	16	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	24400	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	812	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	12	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	2	10
<b>pH</b>	Milligrams per litre	Quarterly	8.1	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	5.31	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	30	30

#### Monitoring Point 4

**Date Sample:** 20 September 2022  
**Date Obtained:** 21 September 2022  
**Date Published:** 22 September 2022

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	72	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	8	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1050	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	57	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	3	10
<b>pH</b>	Milligrams per litre	Quarterly	7.9	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	9.13	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	59	30

#### Monitoring Point 4

**Date Sample:** 14 June 2022  
**Date Obtained:** 9 July 2022  
**Date Published:** 19 July 2022

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	54	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	1480000	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1200	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	62	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	2	10
<b>pH</b>	Milligrams per litre	Quarterly	7.00	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	7.85	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	88	30

#### Monitoring Point 4

**Date Sample:** 12 April 2022

**Date Obtained:** 14 April 2022

**Date Published:** 25 May 2022

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	29	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	1600	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	895	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	45	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	1	10
<b>pH</b>	Milligrams per litre	Quarterly	7.3	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	6.74	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	32	30

#### Monitoring Point 4

**Date Sample:** 11 January 2022

**Date Obtained:** 16 February 2022

**Date Published:** 29 April 2022

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	9	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	1640	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	898	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	25	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	2	10
<b>pH</b>	Milligrams per litre	Quarterly	7.2	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	6.54	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	40	30

#### Monitoring Point 4

**Date Sample:** 8 December 2021

**Date Obtained:** 21 December 2021

**Date Published:** 23 December 2021

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	21	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	211000	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	910	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	27	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	3	10
<b>pH</b>	Milligrams per litre	Quarterly	7.5	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	6.31	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	27	30

#### Monitoring Point 4

**Date Sample:** 25 May 2021

**Date Obtained:** 21 July 2021

**Date Published:** 22 July 2021

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	35	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	356000	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	960	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	48	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	5	10
<b>pH</b>	Milligrams per litre	Quarterly	7.5	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	9.22	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	48	30

#### Monitoring Point 4

**Date Sample:** 22 December 2020

**Date Obtained:** 23 December 2020

**Date Published:** 3 March 2021

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	19	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	222000	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	994	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	53	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	3	10
<b>pH</b>	Milligrams per litre	Quarterly	7.6	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	7.46	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	34	30

#### Monitoring Point 4

**Date Sample:** 20 October 2020

**Date Obtained:** 6 November 2020

**Date Published:** 19 November 2020

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	7	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	111	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	848	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	7	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	1	10
<b>pH</b>	Milligrams per litre	Quarterly	8	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	12.4	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	135	30

#### Monitoring Point 4

**Date Sample:** 23 June 2020

**Date Obtained:** 24 July 2020

**Date Published:** 29 July 2020

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	16	20
Faecal Coliforms	Cfu/100mL	Quarterly	260000	
Conductivity	Microsiemens per centimetre	Quarterly	881	
Nitrogen (total)	Milligrams per litre	Quarterly	34	
Oil and Grease	Milligrams per litre	Quarterly	5	10
pH	Milligrams per litre	Quarterly	6.9	
Phosphorus (total)	Milligrams per litre	Quarterly	8.10	
Total Suspended Solids	Milligrams per litre	Quarterly	123	30

#### Monitoring Point 4

**Date Sample:** 7 April 2020

**Date Obtained:** 4 May 2020

**Date Published:** 5 May 2020

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	49	20
Faecal Coliforms	Cfu/100mL	Quarterly	2000000	
Conductivity	Microsiemens per centimetre	Quarterly	735	
Nitrogen (total)	Milligrams per litre	Quarterly	39	
Oil and Grease	Milligrams per litre	Quarterly	2	10
pH	Milligrams per litre	Quarterly	7.6	
Phosphorus (total)	Milligrams per litre	Quarterly	5.4	
Total Suspended Solids	Milligrams per litre	Quarterly	36	30

#### Monitoring Point 4

**Date Sample:** 28 January 2020

**Date Obtained:** 29 January 2020

**Date Published:** 13 March 2020

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	40	20
Faecal Coliforms	Cfu/100mL	Quarterly	81000	
Conductivity	Microsiemens per centimetre	Quarterly	985	
Nitrogen (total)	Milligrams per litre	Quarterly	43	
Oil and Grease	Milligrams per litre	Quarterly	9	10
pH	Milligrams per litre	Quarterly	7.5	
Phosphorus (total)	Milligrams per litre	Quarterly	7.59	

<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	80	30
-------------------------------	----------------------	-----------	----	----

#### Monitoring Point 4

**Date Sample:** 19 November 2019

**Date Obtained:** 20 November 2019

**Date Published:** 5 January 2020

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	34	20
<b>Faecal Coliforms</b>	Cfu/100mL	Quarterly	<1	
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	890	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	49	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	8	10
<b>pH</b>	Milligrams per litre	Quarterly	7.7	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	10.5	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	40	30

**Date Sample:** 8 October 2019

**Date Obtained:** 14 October 2019

**Date Published:** 19 October 2019

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	<2	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly		
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	2	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	3	10
<b>pH</b>	Milligrams per litre	Quarterly	7.8	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	7.98	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	7	30

**Date Sample:** 19 June 2019

**Date Obtained:** 20 June 2019

**Date Published:** 5 July 2019

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	<2	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	655	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	I/S	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	<1	10
<b>pH</b>	Milligrams per litre	Quarterly	8.5	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	I/S	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	I/S	30



#### Monitoring Point 4

**Date Sample:** 19 May 2019

**Date Obtained:** 22 May 2019

**Date Published:** 6 June 2019

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	40	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	903	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	49	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	11	10
<b>pH</b>	Milligrams per litre	Quarterly	7.5	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	8.28	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	52	30

#### Monitoring Point 4

**Date Sample:** 19 March 2019

**Date Obtained:** 26 March 2019

**Date Published:** 16 April 2019

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	43	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	772	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	34	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	10	10
<b>pH</b>	Milligrams per litre	Quarterly	7.4	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	5.12	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	30	30

#### Monitoring Point 4

**Date Sample:** 26 February 2019

**Date Obtained:** 26 February 2019

**Date Published:** 12 March 2019

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	18	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1020	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	14	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	4	10
<b>pH</b>	Milligrams per litre	Quarterly	7.6	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	7.76	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	695	30

#### Monitoring Point 4

**Date Sample:** 21 August 2018

**Date Obtained:** 21 August 2018

**Date Published:** 11 September 2018

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	<2	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	860	
<b>Faecal Coliforms</b>	Colony forming units per 100 millilitres	Quarterly	70	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	15	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	2	10
<b>pH</b>	Milligrams per litre	Quarterly	7.9	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	8.85	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	20	30

#### Monitoring Point 4

**Date Sample:** 20 March 2018

**Date Obtained:** 20 March 2018

**Date Published:** 13 April 2018

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	58	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1040	
<b>Faecal Coliforms</b>	Colony forming units per 100 millilitres	Quarterly		
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	32	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	1	10
<b>pH</b>	Milligrams per litre	Quarterly	7.8	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	9.3	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	276	30

#### Monitoring Point 4

**Date Sample:** 21 November 2017

**Date Obtained:** 21 November 2017

**Date Published:** 14 December 2017

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	6	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1210	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	9	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	<1	10
<b>pH</b>	Milligrams per litre	Quarterly	7.6	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	15.7	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	33	30

#### Monitoring Point 4

**Date Sample:** 5 September 2017

**Date Obtained:** 19 September 2017

**Date Published:** 3 October 2017

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	7	20
Conductivity	Microsiemens per centimetre	Quarterly	1050	
Nitrogen (total)	Milligrams per litre	Quarterly	31	
Oil and Grease	Milligrams per litre	Quarterly	<1	10
pH	Milligrams per litre	Quarterly	7.7	
Phosphorus (total)	Milligrams per litre	Quarterly	9.18	
Total Suspended Solids	Milligrams per litre	Quarterly	13	30

#### Monitoring Point 4

**Date Sample:** 2 May 2017

**Date Obtained:** 15 May 2017

**Date Published:** 2 June 2017

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	29	20
Conductivity	Microsiemens per centimetre	Quarterly	827	
Nitrogen (total)	Milligrams per litre	Quarterly	40	
Oil and Grease	Milligrams per litre	Quarterly	13	10
pH	Milligrams per litre	Quarterly	7.5	
Phosphorus (total)	Milligrams per litre	Quarterly	6.76	
Total Suspended Solids	Milligrams per litre	Quarterly	29	30

#### Monitoring Point 4

**Date Sample:** 14 March 2017

**Date Obtained:** 22 March 2017

**Date Published:** 24 March 2017

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	33 *	20
Conductivity	Microsiemens per centimetre	Quarterly	1470	
Nitrogen (total)	Milligrams per litre	Quarterly	20	
Oil and Grease	Milligrams per litre	Quarterly	4	10
pH	Milligrams per litre	Quarterly	8.1	
Phosphorus (total)	Milligrams per litre	Quarterly	8.55	
Total Suspended Solids	Milligrams per litre	Quarterly	574*	30

\* Alternative sampling point used and site cleaned two days prior to testing accounts for TSS & BOD levels being high.

m:\combined\environmental services\waste management\pollution monitoring data\archived pollution monitoring data.docx

#### Monitoring Point 4

**Date Sample:** 30 August 2016

**Date Obtained:** 13 September 2016

**Date Published:** 16 September 2016

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Demand</b> <b>Oxygen</b>	Milligrams per litre	Quarterly	4	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	656	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	9	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	3	10
<b>pH</b>	Milligrams per litre	Quarterly	7.7	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	7.33	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	9	30

#### Monitoring Point 4

**Date Sample:** 30 August 2016

**Date Obtained:** 13 September 2016

**Date Published:** 16 September 2016

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Demand</b> <b>Oxygen</b>	Milligrams per litre	Quarterly	4	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	656	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	9	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	3	10
<b>pH</b>	Milligrams per litre	Quarterly	7.7	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	7.33	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	9	30

#### Monitoring Point 4

**Date Sample:** 17 May 2016

**Date Obtained:** 17 May 2016

**Date Published:** 10 June 2016

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Demand</b> <b>Oxygen</b>	Milligrams per litre	Quarterly	12	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	771	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	12	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	1	10
<b>pH</b>	Milligrams per litre	Quarterly	7.6	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	13.6	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	118	30

#### Monitoring Point 4

**Date Sample:** 22 March 2016

**Date Obtained:** 22 March 2016

**Date Published:** 10 June 2016

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Demand	Oxygen Milligrams per litre	Quarterly	13	20
Conductivity	Microsiemens per centimetre	Quarterly	993	
Nitrogen (total)	Milligrams per litre	Quarterly	5	
Oil and Grease	Milligrams per litre	Quarterly	2	10
pH	Milligrams per litre	Quarterly	8.4	
Phosphorus (total)	Milligrams per litre	Quarterly	7.19	
Total Suspended Solids	Milligrams per litre	Quarterly	91	30

#### Monitoring Point 4

**Date Sample:** 1 December 2015

**Date Obtained:** 11 December 2015

**Date Published:** 11 December 2015

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Demand	Oxygen Milligrams per litre	Quarterly	22	20
Conductivity	Microsiemens per centimetre	Quarterly	1220	
Nitrogen (total)	Milligrams per litre	Quarterly	10	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	8.3	
Phosphorus (total)	Milligrams per litre	Quarterly	14.2	
Total Suspended Solids	Milligrams per litre	Quarterly	168	30

#### Monitoring Point 4

**Date Sample:** 18 August 2015

**Date Obtained:** 18 August 2015

**Date Published:** 1 September 2015

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Demand	Oxygen Milligrams per litre	Quarterly	3	20
Conductivity	Microsiemens per centimetre	Quarterly	733	
Nitrogen (total)	Milligrams per litre	Quarterly	15	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	7.9	
Phosphorus (total)	Milligrams per litre	Quarterly	8.23	
Total Suspended Solids	Milligrams per litre	Quarterly	49	30

#### Monitoring Point 4

**Date Sample:** 9 June 2015

**Date Obtained:** 9 June 2015

**Date Published:** 30 June 2015

<b>Pollutant</b>	<b>Unit</b>	<b>Monitoring frequency required by licence</b>	<b>Measurement</b>	<b>Licence Limits</b>
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	2	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	731	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	9	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	2	10
<b>pH</b>	Milligrams per litre	Quarterly	8.0	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	9.41	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	65	30

**Monitoring Point 4**

**Date Sample:** 14 April 2015

**Date Obtained:** 15 April 2015

**Date Published:** 27 April 2015

<b>Pollutant</b>	<b>Unit</b>	<b>Monitoring frequency required by licence</b>	<b>Measurement</b>	<b>Licence Limits</b>
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	11	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	311	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	3	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	2	10
<b>pH</b>	Milligrams per litre	Quarterly	7.2	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	3.83	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	292	30

#### Monitoring Point 4

**Date Sample:** 15 January 2015

**Date Obtained:** 20 January 2015

**Date Published:** 3 February 2015

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	47	20
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	775	
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	40	
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	15	10
<b>pH</b>	Milligrams per litre	Quarterly	7.9	
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	6.88	
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	43	30

#### Monitoring Point 4

**Date Sample:** 14 September 2014

**Date Obtained:** 23 September 2014

**Date Published:** 7 October 2014

Pollutant	Unit	Monitoring frequency required by licence	Measurement
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	74
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	896
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	47
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	18
<b>pH</b>	Milligrams per litre	Quarterly	7.7
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	7.34
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	51

#### Monitoring Point 4

**Date Sample:** 3 June 2014

**Date Obtained:** 17 June 2014

**Date Published:** 18 June 2014

Pollutant	Unit	Monitoring frequency required by licence	Measurement
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	70
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	997
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	27
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	12
<b>pH</b>	Milligrams per litre	Quarterly	7.9
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	5.21
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	60

#### Monitoring Point 4

**Date Sample:** 8 April 2014

**Date Obtained:** 28 April 2014

**Date Published:** 29 April 2014

Pollutant	Unit	Monitoring frequency required by licence	Measurement
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	47
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	684
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	38
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	8
<b>pH</b>	Milligrams per litre	Quarterly	7.5
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	6.34
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	41

#### Monitoring Point 4

**Date Sample:** 14 November 2013

**Date Obtained:** 27 November 2013

**Date Published:** 3 December 2013

Pollutant	Unit	Monitoring frequency required by licence	Measurement
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	29
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	866
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	43
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	6
<b>pH</b>	Milligrams per litre	Quarterly	7.5
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	5.88
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	32

#### Monitoring Point 4

**Date Sample:** 29 August 2013

**Date Obtained:** 12 September 2013

**Date Published:** 18 September 2013

Pollutant	Unit	Monitoring frequency required by licence	Measurement
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	100
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1000
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	46
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	24
<b>pH</b>	Milligrams per litre	Quarterly	7.8
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	7.67
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	73



#### Monitoring Point 4

**Date Sample:** 16 May 2013

**Date Obtained:** 27 May 2013

**Date Published:** 21 May 2013

Pollutant	Unit	Monitoring frequency required by licence	Measurement
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	61
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	738
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	42
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	2
<b>pH</b>	Milligrams per litre	Quarterly	7.3
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	5.99
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	54

#### Monitoring Point 4

**Date Sample:** 21 March 2013

**Date Obtained:** 4 April 2013

**Date Published:** 8 April 2013

Pollutant	Unit	Monitoring frequency required by licence	Measurement
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	31
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	839
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	33
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	17
<b>pH</b>	Milligrams per litre	Quarterly	7.2
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	5.99
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	34

#### Monitoring Point 4

**Date Sample:** 14 November 2012

**Date Obtained:** 27 November 2012

**Date Published:** 4 December 2012

Pollutant	Unit	Monitoring frequency required by licence	Measurement
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	71
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	914
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	51
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	1
<b>pH</b>	Milligrams per litre	Quarterly	7.7
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	7.2
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	43

#### Monitoring Point 4

**Date Sample:** 16 August 2012

**Date Obtained:** 28 August 2012

**Date Published:** 31 August 2012

Pollutant	Unit	Monitoring frequency required by licence	Measurement
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	100
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1020
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	47
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	20
<b>pH</b>	Milligrams per litre	Quarterly	8.0
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	8.4
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	64

#### Monitoring Point 4

**Date Sample:** 20 June 2012

**Date Obtained:** 3 July 2012

**Date Published:** 5 July 2012

Pollutant	Unit	Monitoring frequency required by licence	Measurement
<b>Biochemical Oxygen Demand</b>	Milligrams per litre	Quarterly	101
<b>Conductivity</b>	Microsiemens per centimetre	Quarterly	1090
<b>Nitrogen (total)</b>	Milligrams per litre	Quarterly	83
<b>Oil and Grease</b>	Milligrams per litre	Quarterly	17
<b>pH</b>	Milligrams per litre	Quarterly	7.6
<b>Phosphorus (total)</b>	Milligrams per litre	Quarterly	8.04
<b>Total Suspended Solids</b>	Milligrams per litre	Quarterly	54