

POLLUTION MONITORING DATA
Jerilderie Sewerage Treatment Works



Environment Protection Licence No. 1692

Link to full licence on EPA website: [Jerilderie Licence 1692](#)

Licensee: Murrumbidgee Council

Licensee's Address: PO Box 96, Jerilderie NSW 2716

Facility Address: Wilson Road, Jerilderie NSW 2716

Date Sample: 4 December 2024

Date Obtained: 5 December 2024

Date Published: 18 December 2024

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	7	20
Faecal Coliforms	Cfu/100mL	Quarterly	121	
Conductivity	Microsiemens per centimetre	Quarterly	1200	
Nitrogen (total)	Milligrams per litre	Quarterly	12	
Oil and Grease	Milligrams per litre	Quarterly	3	10
pH	Milligrams per litre	Quarterly	8.1	
Phosphorus (total)	Milligrams per litre	Quarterly	14.8	
Total Suspended Solids	Milligrams per litre	Quarterly	388	30