


POLLUTION MONITORING DATA
Jerilderie Sewerage Treatment Works



Environment Protection Licence No. 1692

Link to full licence on EPA website: [Jerilderie Licence 1692](#)

Licensee: Murrumbidgee Council

Licensee's Address: PO Box 96, Jerilderie NSW 2716

Facility Address: Wilson Road, Jerilderie NSW 2716

Date Sample: 5 December 2023

Date Obtained: 11 December 2023

Date Published: 21 December 2023

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	22	20
Faecal Coliforms	Cfu/100mL	Quarterly	10	
Conductivity	Microsiemens per centimetre	Quarterly	672	
Nitrogen (total)	Milligrams per litre	Quarterly	8	
Oil and Grease	Milligrams per litre	Quarterly	1	10
pH	Milligrams per litre	Quarterly	9.5	
Phosphorus (total)	Milligrams per litre	Quarterly	1.89	
Total Suspended Solids	Milligrams per litre	Quarterly	6	30