


POLLUTION MONITORING DATA
Jerilderie Sewerage Treatment Works



Environment Protection Licence No. 1692

Link to full licence on EPA website: [Jerilderie Licence 1692](#)

Licensee: Murrumbidgee Council

Licensee's Address: PO Box 96, Jerilderie NSW 2716

Facility Address: Wilson Road, Jerilderie NSW 2716

Monitoring Point 4

Date Sample: 21 August 2018

Date Obtained: 21 August 2018

Date Published: 11 September 2018

Pollutant	Unit	Monitoring frequency required by licence	Measurement	Licence Limits
Biochemical Oxygen Demand	Milligrams per litre	Quarterly	<2	20
Conductivity	Microsiemens per centimetre	Quarterly	860	
Faecal Coliforms	Colony forming units per 100 millilitres	Quarterly	70	
Nitrogen (total)	Milligrams per litre	Quarterly	15	
Oil and Grease	Milligrams per litre	Quarterly	2	10
pH	Milligrams per litre	Quarterly	7.9	
Phosphorus (total)	Milligrams per litre	Quarterly	8.85	
Total Suspended Solids	Milligrams per litre	Quarterly	20	30